

Bill History
Session Year 2012
Raised H.B. No. 5383

[Bill Analysis for File Copy 185](#) [File No. 185 \[pdf\]](#)
[Fiscal Note for File Copy 185](#) [Raised Bill \[pdf\]](#)
[PS Joint Favorable \[pdf\]](#) [PS Vote Tally Sheet \[pdf\]](#)

Introducer(s):

Public Safety and Security Committee

Title: AN ACT REQUIRING CARBON MONOXIDE AND OXYGEN SENSORS ON PORTABLE ELECTRIC GENERATORS.

Statement of Purpose: To ensure the safety of persons using portable electric generators by requiring such generators to be equipped with sensors that will automatically shut down the generator when it is used in an enclosed space where carbon monoxide levels rise and oxygen levels drop.

Bill History:

02/29/12 REFERRED TO JOINT COMMITTEE ON Public Safety and Security Committee
03/02/12 PUBLIC HEARING 03/06
03/15/12 JOINT FAVORABLE
03/15/12 FILED WITH LEGISLATIVE COMMISSIONERS' OFFICE
03/23/12 REFERRED TO OFFICE OF LEGISLATIVE RESEARCH AND OFFICE OF FISCAL ANALYSIS 03/28/12-5:00 PM
03/29/12 REPORTED OUT OF LEGISLATIVE COMMISSIONERS' OFFICE
03/29/12 FAVORABLE REPORT, TABLED FOR THE CALENDAR, HOUSE
03/29/12 HOUSE CALENDAR NUMBER 152
03/29/12 FILE NUMBER 185

Co-sponsor(s):

Rep. Marie Lopez Kirkley-Bey, 5th Dist. Rep. Mary G. Fritz, 90th Dist.